

Technical Notified



No.: 21-011B

SS2 inverter CPU firmware upgrade description

Thank you for choosing and supporting Shihlin Electric products. For SS2 inverter CPU software upgrade, the instructions are as follows:

A. Objective models:

SS2 Series inverter

B. Change identification

| Item | Before | After | |
|------------------|--|--|--|
| P.1457 | 0.500 | 0.510 | |
| Product Label | Style No.: SS2-021-0.4K Input : 6.5A 1PH AC200~240V 50/60Hz Output : 2.7A MAX 3PH AC200~240V 0.4kW FREQ. Range : 0.1~650Hz IP20 S/N : S2AACAS17L0001 VER: 0.500A | Style No.: SS2-021-0.4K Input : 6.5A 1PH AC200~240V 50/60Hz Output : 2.7A MAX 3PH AC200~240V 0.4kW FREQ. Range : 0.1~599Hz IP20 S/N : S2AACAS17L0001 VER: 0.510A | |

C、New addition & modification

| N | lo. | Contents | |
|---|-----|--|--|
| | 1 | Added 1-8-N-1 frame format communication protocol; | |
| | 2 | Changed Max. output frequency from 650Hz to 599Hz | |

Note: It is recommended to use SS2 series operation manual V1.09 or above.

D. Effective date

1. The alternative period will be implemented from November 2021.

| Date /2021 Title firmware upgrade Shihlin Electric Automation description | Release Date | 11/26 /2021 Titl | 'J | Shihlin Electric Automation Group |
|---|-----------------|---------------------|----|-----------------------------------|
|---|-----------------|---------------------|----|-----------------------------------|